FUEL TANK PACKAGES

Standard Features

Above ground tanks with secondary containment Built to UL 142 Specifications Urethane primer / Top coat enamel Vent Package (see detail below)

Terre a desirable (see a detain select)			
STOCK CODE	FUEL TANK SIZES	WEIGHT #'S	
GKFT460250-11	250 Gallon Tank	850	
GKFT460500-11	500 Gallon Tank	1257	
GKFT460500-22	250/250 Gallon Split Tank	1583	
GKFT640750-11	750 Gallon Tank	1704	
GKFT461000-22	500/500 Gallon Split Tank	2425	
GKFT641000-11	1000 Gallon Tank	1869	
GKFT641500-11	1500 Gallon Tank	2916	
GKFT641500-22	750/750 Gallon Split Tank	3233	
GKFT641500-23	1000/500 Gallon Split Tank	3400	
GKFT642000-11	2000 Gallon Tank	3542	
GKFT642000-22	1000/1000 Gallon Split Tank	3562	
GKFT642000-24	1500/500 Gallon Split Tank	3999	
GKFT642500-11	2500 Gallon Tank	4211	
GKFT642500-24	2000/500 Gallon Split Tank	4658	
GKFT643000-11	3000 Gallon Tank	4808	
GKFT643500-11	3500 Gallon Tank	5449	
GKFT965000-11	5000 Gallon Tank	10694	
GKFT966000-11	6000 Gallon Tank	11176	
GKFT9612000-11	12000 Gallon Tank	18900	
GKFT10818000-11	18000 Gallon Tank	25500	
Accessories			

Accessories			
MASC110-GK46"	46" Pump installed		
MASC119-GK64"	64" Pump installed		
MASC119-GK72"	72" Pump installed		
MASC119A	FILL RITE 311VB, WITH METER-35 GPM, 1	15VAC	
SPRAY117H-GK	Nozzle Diesel		
SPRAY117D	NOZZLE DIESEL WITH GREEN HANDLE IN PARTS		
SPRAY116H-GK	Nozzle Gas		
GKFT460048	*Downcomer - Built to order		
GKFT460048	*Downcomer - Installed after tank built		
GKFT640048	*Downcomer -Built to order		
GKFT640048	*Downcomer - Installed after tank built		
GKFT960001	Drop Down Kit - 30 gal. pump		
GKFT960002	96" Ladder Kit (large units)		
GKFT960003	Drop Down Kit - 20 gal. pump		
FT640028	Security Pump Cover		

Vent Package Includes:

Emergency vents, Fill can with spill containment, Fluid level gauge (primary tank), Leak Indicator (secondary)

Updraft vents (12' above ground)

SPLIT TANKS REQUIRE TWO PUMPS & DOUBLE ACCESSORIES

^{*}Downcomer Note: Gasoline tanks - State of Oregon requires a downcomer fill pipe

^{*}Standard tanks built for stock are Diesel fuel and do not have downcomver fill pipe installed

^{*}Add two weeks leadtime if stock tank sold for Gasoline storage